

---

**ROOM DETAILS:**

---

NATURE OF ACTIVITIES: Cleaners Storage  
ROOM SIZE (M<sup>2</sup>): 2  
OCCUPANTS: MAX: Transient MIN: Transient  
OCCUPANCY PERIODS: N/A  
CEILING TYPE: 600x600 Suspended Ceiling

---

**ENVIRONMENTAL CONDITION:**

---

WINTER: DAY: 16 °C db  
NIGHT: N/A °C db  
SUMMER: N/A °C db

---

**DRAINAGE:**

---

FOUL DRAINAGE: Yes  
LABORATORY DRAINAGE: None  
RAINWATER DRAINAGE: None  
OTHER: None

---

**PIPED SUPPLY SYSTEM:**

---

WATER: COLD: Yes DRINKING: None  
HOT: Yes  
APPLIANCES: BASIN: None URINAL: None  
WC: None SHOWER: None  
OTHER: 1no. sink  
COMPRESSED AIR: None  
WET/DRY RISER: None  
SPRINKLERS: None  
OTHER: None

---

**VENTILATION AND NOISE REQUIREMENT:**

---

VENTILATION RATE: 5 ACH  
ROOM PRESSURE: Negative  
NOISE LEVEL: N/A  
SPECIAL REQUIREMENT: Mechanical extract c/w PIR control and 15 minute overrun timer

---

**HEATING:**

---

SYSTEM TYPE: None  
SYSTEM CONTROL: None

**COOLING:**

---

SYSTEM TYPE: None  
SYSTEM CONTROL: None

**GENERAL AND EMERGENCY LIGHTING:**

---

ILLUMINATION LEVEL: 200 (LUX) GLARE INDEX: 25  
MOUNTING TYPE: Surface MOUNTING HEIGHT: Ceiling WORKING PLANE: Floor  
LUMINAIRE TYPE: LS2 LAMP TYPE: LED  
CONTROL TYPE: Presence Detection EMERGENCY LIGHTING: To BS 5266-1  
SPECIAL REQUIREMENT: None

**GENERAL LV POWER:**

---

THREE PHASE SUPPLIES: None  
SWITCHED SOCKET OUTLET (SSO): None 230V DOUBLE SWITCHED SOCKET OUTLET (DSSO) None  
UNIVERSAL SERIAL BUS (USB) SOCKET OUTLET: None  
LV SUPPLIES: Extract fan  
SPECIAL REQUIREMENT: None  
UNINTERRUPTIBLE POWER SUPPLY (UPS): None

**COMMUNICATIONS:**

---

TELEPHONE OUTLET: None TELEVISION/RADIO OUTLET: None  
TWIN DATA OUTLET: None SPECIAL FACILITIES: None

---

**ACCESS CONTROL:**

---

PROXIMITY CARD/FOB:	None	DIGILOCK KEYPAD:	None
---------------------	------	------------------	------

---

**SECURITY DETECTION AND ALARM:**

---

MOTION DETECTOR:	None	DOOR CONTACT:	None
VIBRATION SENSOR:	None	WINDOW CONTACT:	None

---

**CLOSED CIRCUIT TELEVISION (CCTV):**

---

FIXED CAMERA:	None	FULLY FUNCTIONAL CAMERA	None
MOUNTING TYPE:	None		

---

**FIRE DETECTION & ALARM SYSTEM (FD&AS):**

---

MANUAL CALL POINT:	None	AUDIBLE SOUNDER:	To BS 5839
SMOKE DETECTION:	To BS 5839	HEAT DETECTION:	None
VISUAL ALARM DEVICES	None	FIRE ALARM INTERFACE:	None

---

**PUBLIC ADDRESS VOICE ALARM (PAVA):**

---

SPEAKER TYPE:	None	LOCAL VOLUME CONTROL:	None
---------------	------	-----------------------	------

---

**EARTHING, BONDING, EMC MEASURES AND SURGE PROTECTION:**

---

EARTHING/BONDING:	To BS 7671	CLEAN EARTH:	None
-------------------	------------	--------------	------

---

**CENTRAL CONTROL/BUILDING MANAGEMENT:**

---

None.

---

**NOTES:**

---