
ROOM DETAILS:

NATURE OF ACTIVITIES: Circulation
ROOM SIZE (M²): 11
OCCUPANTS: MAX: Transient MIN: Transient
OCCUPANCY PERIODS: 8:00AM – 11:00PM
CEILING TYPE: 600x600 Suspended ceiling

ENVIRONMENTAL CONDITION:

WINTER: DAY: 19-21 °C db
NIGHT: 10 °C db
SUMMER: N/A °C db

DRAINAGE:

FOUL DRAINAGE: None
LABORATORY DRAINAGE: None
RAINWATER DRAINAGE: None
OTHER: None

PIPED SUPPLY SYSTEM:

WATER: COLD: None DRINKING: None
HOT: None
APPLIANCES: BASIN: None URINAL: None
WC: None SHOWER: None
OTHER: None
COMPRESSED AIR: None
WET/DRY RISER: None
SPRINKLERS: None
OTHER: None

VENTILATION AND NOISE REQUIREMENT:

VENTILATION RATE: None
ROOM PRESSURE: Neutral
NOISE LEVEL: NR35
SPECIAL REQUIREMENT: None

HEATING:

SYSTEM TYPE: Underfloor heating
SYSTEM CONTROL: Local wall mounted controller

COOLING:

SYSTEM TYPE: None
SYSTEM CONTROL: None

GENERAL AND EMERGENCY LIGHTING:

ILLUMINATION LEVEL: 200 (LUX) GLARE INDEX: 22
MOUNTING TYPE: Recessed MOUNTING HEIGHT: Ceiling WORKING PLANE: 0.75m
LUMINAIRE TYPE: SR1 LAMP TYPE: LED
CONTROL TYPE: Presence Detection EMERGENCY LIGHTING: To BS 5266-1
SPECIAL REQUIREMENT: LED emergency directional signage.

GENERAL LV POWER:

THREE PHASE SUPPLIES: None
SWITCHED SOCKET OUTLET (SSO): 1no. cleaners socket 230V DOUBLE SWITCHED SOCKET OUTLET (DSSO) None
UNIVERSAL SERIAL BUS (USB) SOCKET OUTLET: None
LV SUPPLIES: Overdoor heaters
Fire alarm control & indicating equipment panel
Door entry system
SPECIAL REQUIREMENT: None
UNINTERRUPTIBLE POWER SUPPLY (UPS): None

COMMUNICATIONS:

TELEPHONE OUTLET:	None	TELEVISION/RADIO OUTLET:	None
TWIN DATA OUTLET	None	SPECIAL FACILITIES:	None

ACCESS CONTROL:

PROXIMITY CARD/FOB:	None	DIGILOCK KEYPAD:	None
---------------------	------	------------------	------

SECURITY DETECTION AND ALARM:

MOTION DETECTOR:	Digital Dual Technology PIR Detector	DOOR CONTACT:	None
VIBRATION SENSOR:	None	WINDOW CONTACT:	None

CLOSED CIRCUIT TELEVISION (CCTV):

FIXED CAMERA:	Yes. Fixed dome CCTV.	FULLY FUNCTIONAL CAMERA	None
MOUNTING TYPE:	Ceiling		

FIRE DETECTION & ALARM SYSTEM (FD&AS):

MANUAL CALL POINT:	To BS 5839	AUDIBLE SOUNDER:	To BS 5839
SMOKE DETECTION:	To BS 5839	HEAT DETECTION:	None
VISUAL ALARM DEVICES	None	FIRE ALARM INTERFACE:	To BS 5839

PUBLIC ADDRESS VOICE ALARM (PAVA):

SPEAKER TYPE:	None	LOCAL VOLUME CONTROL:	None
---------------	------	-----------------------	------

EARTHING, BONDING, EMC MEASURES AND SURGE PROTECTION:

EARTHING/BONDING:	To BS 7671	CLEAN EARTH:	None
-------------------	------------	--------------	------

CENTRAL CONTROL/BUILDING MANAGEMENT:

None

NOTES:

1. Security keypad.