
ROOM DETAILS:

NATURE OF ACTIVITIES: Car parking/Circulation
ROOM SIZE (M²): N/A
OCCUPANTS: MAX: N/A MIN: N/A
OCCUPANCY PERIODS: Various, over a Twenty Four [24] hour period.
CEILING TYPE: N/A

ENVIRONMENTAL CONDITION:

WINTER: DAY: N/A °C db
NIGHT: N/A °C db
SUMMER: N/A °C db

DRAINAGE:

FOUL DRAINAGE: None
LABORATORY DRAINAGE: None
RAINWATER DRAINAGE: None
OTHER: None

PIPED SUPPLY SYSTEM:

WATER: COLD: None DRINKING: None
HOT: None
APPLIANCES: BASIN: None URINAL: None
WC: None SHOWER: None
COMPRESSED AIR: None.
WET/DRY RISER: None.
SPRINKLERS: None.
OTHER: 1no external bib tap with backflow prevention and lock box cover.

VENTILATION AND NOISE REQUIREMENT:

VENTILATION RATE: None
ROOM PRESSURE: None
NOISE LEVEL: None
SPECIAL REQUIREMENT: None

HEATING:

SYSTEM TYPE: Mitsubishi Air Source Heat Pump (Outdoor Unit)
SYSTEM CONTROL: None

COOLING:

SYSTEM TYPE: None
SYSTEM CONTROL: None

GENERAL AND EMERGENCY LIGHTING:

ILLUMINATION LEVEL: 10-15 (LUX) UNIFORMITY: 0.25

MOUNTING TYPE: Wall mounted MOUNTING HEIGHT: 2500mm WORKING PLANE: Floor level

LUMINAIRE TYPE: XR1 & XR2 LAMP TYPE: LED

CONTROL TYPE: Photocell/PIR Timeclock EMERGENCY LIGHTING: integral emergency fittings.

SPECIAL REQUIREMENT: Override locally for integrated photocell/PIR and central timeclock, Manual ON/OFF

GENERAL LV POWER:

THREE PHASE SOCKET OUTLET: 1 no for Inverter Heat Pump
230V DOUBLE SWITCHED SOCKET OUTLET (DSSO): None
UNIVERSAL SERIAL BUS (USB) SOCKET OUTLET: None
LV SOCKET OUTLET: None
SPECIAL REQUIREMENT: 1 no 32A IP65 isolator for mechanical plant
UNINTERRUPTIBLE POWER SUPPLY (UPS): None

COMMUNICATIONS:

TELEPHONE OUTLET: None TELEVISION/RADIO OUTLET: None
TWIN DATA OUTLET: None SPECIAL FACILITIES: None

ACCESS CONTROL:

PROXIMITY CARD/FOB: Yes DIGILOCK KEYPAD: None

SECURITY DETECTION AND ALARM:

MOTION DETECTOR: None DOOR CONTACT: None
VIBRATION SENSOR: None WINDOW CONTACT: None

CLOSED CIRCUIT TELEVISION (CCTV):

FIXED CAMERA: 3no Dome Type Cameras FULLY FUNCTIONAL CAMERA None
MOUNTING TYPE: Wall mounted

FIRE DETECTION & ALARM SYSTEM (FD&AS):

MANUAL CALL POINT: None AUDIBLE SOUNDER: None
SMOKE DETECTION: None HEAT DETECTION: None
VISUAL ALARM DEVICES To Bs5839 FIRE ALARM INTERFACE: None

PUBLIC ADDRESS VOICE ALARM (PAVA):

SPEAKER TYPE: None LOCAL VOLUME CONTROL: None

EARTHING, BONDING, EMC MEASURES AND SURGE PROTECTION:

EARTHING/BONDING: None CLEAN EARTH: None

CENTRAL CONTROL/BUILDING MANAGEMENT:

None.

NOTES:

1. CCTV to be installed to cover all doors.